

VILLAGE OF EAST AURORA
716-652-6057 DPW

Department of Public Works
Application for Sewer Tap and/or Storm Sewer Connection

Application Fee \$25.00
Permit Fee – Class A Residential \$450.00
Class B Commercial/Industrial \$500.00
Permit Fee – Storm Sewer Connection \$200.00

Date _____
Receipt # _____

I/We _____, hereby make application for:

Class _____ Sewer Tap and/or
_____ Storm Sewer Connection

to be installed at _____ under the supervision of an authorized agent of the Village of East Aurora at a cost of \$_____.

I/We agree that all piping between the street line and structure to be of Cast Iron, Concrete Sewer Pipe, or PVC Schedule 35 or equal having a wall thickness of .120" for 4", integral gasket type, bedded in at least 6" of select fill.

That: All pipes will be cast iron coming through foundation up to and including the 1st cleanout & trap.

That: All traps and cleanouts must be a minimum of 10' (ten feet) from foundation.

That: Sewer pipe shall be located no less than 2' (two feet) from water service pipe.

That: an authorized agent of the Village must inspect Sewer piping, before the pipe is covered, or trench filled.

That: The Building Inspector and the Public Works Department must be notified when installation is ready for inspection. (Inspections to be made between 8:00 A.M. and 3:00 P.M.)

Pipe shall be placed on a full trench width (minimum width 12" wider than pipe) 6" thick bedding of stone.

Stone backfill shall be placed full trench width from stone bedding for a minimum of 6" depth over pipe.

Stone shall be 3/8" crushed limestone or washed crushed gravel of equal size.

Connections to Village Line are to be a FURNCO coupling or Pipe Manufacturers Adaptor.

Date: _____
_____ (Signature of Applicant)

Tap Made: _____ Service Line Inspected & Found Satisfactory

By: _____ Date: _____

Application for Sewer Service Disconnection

Date: _____ **Pd.** _____
Application Fee: \$25.00 **Permit Fee: \$200.000** **Receipt #** _____
(Clerk's Office)

I/We _____, owners of the property at _____, East Aurora, New York, hereby apply to the Village of East Aurora for disconnection of sewer service line at the above address. The building is planned for demolition, which is to commence on _____ 20____. (Allow one-week time from filing of this application.)

All sewer disconnects shall be made by the owner's contractor. Once completed, the disconnect shall be inspected jointly by the Department of Public Works and Erie County Sewer District. Please call the Department of Public Works @ 652-6057 to schedule inspection.

(Signature of Owner)

Service Disconnect Inspected & Found Satisfactory by: _____

Date of Inspection: _____